

To: All Plan Holders of Record

From: CT Consultants, Inc.
For the Owner

**Re: Addendum No. 1
Community Center Generator
City of Willowick**

Date: June 10, 2024

This Addendum forms a part of the contract documents and modifies the original bidding documents dated May 2024 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

QUESTIONS AND ANSWERS

Q1. Will a natural gas fueled generator be permitted as an approved substitute versus the specified diesel fueled generator?

A1. Yes, if a proposed natural gas generator system meets the requirements needed to provide power the Community Center, the City will accept this as an approved equivalent. The Contractor will be responsible to include any additional improvements, including coordination with utilities, installation of conduit to supply the generator with a natural gas feed, and any and all improvements needed to install the generator and restore the property to it's existing condition.

Q2. Will Generac, Cummins, or CAT be approved alternates?

A2: Yes. The City will accept these manufacturers with the assumption they meet the necessary power and load outputs required to fully power the community center.

Q3. Does an engineer need to stamp the drawings or submittals?

A3: Yes. This can come directly from the Contactor or Manufacturer with a qualification that the Engineer is licensed in the State of Ohio.

TM:mep

Enclosures

H:\2024\241620\SPEC\Addenda\Addendum 01\Addendum 01.Doc