

SECTION 087100 - DOOR HARDWARE

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes items known commercially as finish or door hardware that are required for swing, sliding, and folding doors, except special types of unique hardware specified in the same sections as the doors and door frames on which they are installed.

- B. This Section includes the following:

1. Hinges.
2. Lock and latch sets.
3. Bolts.
4. Exit devices.
5. Closers.
6. Overhead holders.
7. Weather-stripping for exterior doors.
8. Astragals or meeting seals on pairs of doors.
9. Thresholds.
10. Electric Strikes

- C. Related Sections: The following Sections contain requirements that relate to this Section:

1. Division 8 Section "Steel Doors and Frames" for silencers integral with hollow metal frames.

1.3 SUBMITTALS

- A. General: Submit the following in accordance with Conditions of Contract and Division 1 Specification sections.
- B. Product data including manufacturers' technical product data for each item of door hardware, installation instructions, maintenance of operating parts and finish, and other information necessary to show compliance with requirements.
- C. Final hardware schedule coordinated with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of door hardware.

1. Final Hardware Schedule Content: Based on hardware indicated, organize schedule into "hardware sets" indicating complete designations of every item required for each door or opening. Include the following information:
 - a. Type, style, function, size, and finish of each hardware item.
 - b. Name and manufacturer of each item.
 - c. Fastenings and other pertinent information.
 - d. Location of each hardware set cross referenced to indications on Drawings both on floor plans and in door and frame schedule.
 - e. Explanation of all abbreviations, symbols, and codes contained in schedule.
 - f. Mounting locations for hardware.
 - g. Door and frame sizes and materials.
 - h. Keying information.
2. Submittal Sequence: Submit final schedule at earliest possible date particularly where acceptance of hardware schedule must precede fabrication of other work that is critical in the Project construction schedule. Include with schedule the product data, samples, shop drawings of other work affected by door hardware, and other information essential to the coordinated review of schedule.

- D. Templates for doors, frames, and other work specified to be factory prepared for the installation of door hardware. Check shop drawings of other work to confirm that adequate provisions are made for locating and installing door hardware to comply with indicated requirements.

1.4 QUALITY ASSURANCE

- A. Single Source Responsibility: Obtain each type of hardware (latch and lock sets, hinges, closers, etc.) from a single manufacturer.
- B. Supplier Qualifications: A recognized architectural door hardware supplier, with warehousing facilities in the Project's vicinity, that has a record of successful in-service performance for supplying door hardware similar in quantity, type, and quality to that indicated for this Project and that employs an experienced architectural hardware consultant (AHC) who is available to Owner, Architect, and Contractor, at reasonable times during the course of the Work, for consultation.
 1. Require supplier to meet with Owner to finalize keying requirements and to obtain final instructions in writing.

1.5 PRODUCT HANDLING

- A. Tag each item or package separately with identification related to final hardware schedule, and include basic installation instructions with each item or package.

- B. Packaging of door hardware is responsibility of supplier. As material is received by hardware supplier from various manufacturers, sort and repackage in containers clearly marked with appropriate hardware set number to match set numbers of approved hardware schedule. Two or more identical sets may be packed in same container.
- C. Inventory door hardware jointly with representatives of hardware supplier and hardware installer until each is satisfied that count is correct.
- D. Deliver individually packaged door hardware items promptly to place of installation (shop or Project site).
- E. Provide secure lock-up for door hardware delivered to the Project, but not yet installed. Control handling and installation of hardware items that are not immediately replaceable so that completion of the Work will not be delayed by hardware losses both before and after installation.

1.6 MAINTENANCE

- A. Maintenance Tools and Instructions: Furnish a complete set of specialized tools and maintenance instructions as needed for Owner's continued adjustment, maintenance, and removal and replacement of door hardware.

1.7 COORDINATION

- A. Security: Coordinate installation of door hardware, keying and access control with Owner's security requirements.
- B. Electrical System Roughing-In: Coordinate layout and installation of electrified door hardware with connections to power supplies and building safety and security systems.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Butts and Hinges:
 - a. Bommer Industries, Inc.
 - b. Cal-Royal Products, Inc.
 - c. Hager Hinge Co.
 - d. Lawrence Brothers, Inc.
 - e. McKinney Products Co.
 - f. H. Soss & Company.
 - g. Stanley Hardware, Div. Stanley Works.

2. Locks:
 - a. Arrow Lock Manufacturing Co.
 - b. Best Lock Corp.
 - c. Corbin & Russwin Architectural Hardware, Div. Black & Decker Corp.
 - d. Falcon Lock Co.
 - e. Sargent Manufacturing Company.
 - f. Schlage Lock, Div. Ingersoll-Rand Door Hardware Group.
 - g. Yale Security Inc.

3. Bolts:
 - a. Builders Brass Works Corp.
 - b. Glynn-Johnson Corp.
 - c. Hager Hinge Co.
 - d. H. B. Ives, A Harrow Company.
 - e. Quality Hardware Mfg. Co., Inc.; Div. Newman Tonks, Inc.
 - f. Stanley Hardware, Div. Stanley Works.

4. Exit/Panic Devices:
 - a. Adams Rite Manufacturing Co.
 - b. Arrow Lock Manufacturing Co.
 - c. Corbin & Russwin Architectural Hardware, Div. Black & Decker Corp.
 - d. Dor-O-Matic.
 - e. Monarch Hardware & Mfg. Co., Div Newman Tonks, Inc.
 - f. Precision Hardware, Inc.
 - g. Reed Exit Hardware, Div. Yale Security Inc.
 - h. Sargent Manufacturing Company.
 - i. Von Duprin, Div. Ingersoll-Rand Door Hardware Group.
 - j. Yale Security Inc.

5. Overhead Closers:
 - a. Arrow Lock Manufacturing Co.
 - b. Corbin & Russwin Architectural Hardware, Div. Black & Decker Corp.
 - c. Dorma Door Controls International.
 - d. International Door Closers, Inc.
 - e. LCN, Div. Ingersoll-Rand Door Hardware Group.
 - f. Monarch Hardware & Mfg. Co., Div Newman Tonks, Inc.
 - g. Norton Door Controls, Div. Yale Security Inc.
 - h. Rixson-Firemark, Div. Yale Security Inc.
 - i. Sargent Manufacturing Company.
 - j. Yale Security Inc.

6. Door Control Devices:
 - a. Baldwin Hardware Corp.
 - b. Brookline Industries, Div. Yale Security Inc.
 - c. Builders Brass Works Corp.
 - d. Corbin & Russwin Architectural Hardware, Div. Black & Decker Corp.
 - e. Glynn-Johnson Corp.

- f. Hager Hinge Co.
 - g. H. B. Ives, A Harrow Company.
 - h. Quality Hardware Mfg. Co., Inc.; Div. Newman Tonks, Inc.
 - i. Triangle Brass Manufacturing Company (Trimco).
7. Kick, Mop, and Armor Plates:
- a. Baldwin Hardware Corp.
 - b. Brookline Industries, Div. Yale Security Inc.
 - c. Corbin & Russwin Architectural Hardware, Div. Black & Decker Corp.
 - d. Hager Hinge Co.
 - e. Hiawatha, Inc.
 - f. H. B. Ives, A Harrow Company.
 - g. Triangle Brass Manufacturing Company (Trimco).
8. Door Stripping and Seals:
- a. Hager Hinge Co.
 - b. National Guard Products, Inc.
 - c. Pemko Manufacturing Co., Inc.
 - d. Reese Enterprises, Inc.
 - e. Sealeze Corp.
 - f. Ultra Industries.
 - g. Zero International, Inc.
9. Thresholds:
- a. Hager Hinge Co.
 - b. National Guard Products, Inc.
 - c. Pemko Manufacturing Co., Inc.
 - d. Reese Enterprises, Inc.
 - e. Sealeze Corp.
 - f. Zero International, Inc.
10. Automatic Drop Seals:
- a. Hager Hinge Co.
 - b. National Guard Products, Inc.
 - c. Pemko Manufacturing Co., Inc.
 - d. Reese Enterprises, Inc.
 - e. Zero International, Inc.

2.2 SCHEDULED HARDWARE

- A. Requirements for design, grade, function, finish, size, and other distinctive qualities of each type of finish hardware are indicated in the "Hardware Schedule" at the end of this Section. Products are identified by using hardware designation numbers of the following:
- 1. Manufacturer's Product Designations: The product designation and name of one manufacturer are listed for each hardware type required for the purpose of establishing minimum requirements. Provide either the product designated or, where more than one manufacturer is specified under the Article "Manufacturers" in Part 2

for each hardware type, the comparable product of one of the other manufacturers that complies with requirements.

- B. Electrified Door Hardware: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.

2.3 MATERIALS AND FABRICATION

- A. Manufacturer's Name Plate: Do not use manufacturers' products that have manufacturer's name or trade name displayed in a visible location (omit removable nameplates) except in conjunction with required fire-rated labels and as otherwise acceptable to Architect.
 - 1. Manufacturer's identification will be permitted on rim of lock cylinders only.
- B. Base Metals: Produce hardware units of basic metal and forming method indicated using manufacturer's standard metal alloy, composition, temper, and hardness, but in no case of lesser (commercially recognized) quality than specified for applicable hardware units for finish designations indicated.
- C. Fasteners: Provide hardware manufactured to conform to published templates, generally prepared for machine screw installation. Do not provide hardware that has been prepared for self-tapping sheet metal screws, except as specifically indicated.
- D. Furnish screws for installation with each hardware item. Provide Phillips flat-head screws except as otherwise indicated. Finish exposed (exposed under any condition) screws to match hardware finish or, if exposed in surfaces of other work, to match finish of this other work as closely as possible including "prepared for paint" surfaces to receive painted finish.
- E. Provide concealed fasteners for hardware units that are exposed when door is closed except to the extent no standard units of type specified are available with concealed fasteners. Do not use thru-bolts for installation where bolt head or nut on opposite face is exposed in other work unless their use is the only means of reinforcing the work adequately to fasten the hardware securely. Where thru-bolts are used as a means of reinforcing the work, provide sleeves for each thru-bolt or use sex screw fasteners.

2.4 HINGES

- A. Templates: Except for hinges and pivots to be installed entirely (both leaves) into wood doors and frames, provide only template-produced units.
- B. Screws: Provide Phillips flat-head screws complying with the following requirements:
 - 1. For metal doors and frames install machine screws into drilled and tapped holes.
 - 2. For wood doors and frames install wood screws.
 - 3. For fire-rated wood doors install #12 x 1-1/4-inch (32-mm), threaded-to-the-head steel wood screws.
 - 4. Finish screw heads to match surface of hinges or pivots.

- C. Hinge Pins: Except as otherwise indicated, provide hinge pins as follows:
1. Out-Swing Exterior Doors: Nonremovable pins.
 2. Out-Swing Corridor Doors with Locks: Nonremovable pins.
 3. Interior Doors: Nonrising pins.
 4. Tips: Flat button and matching plug, finished to match leaves, except where hospital tip (HT) indicated.
- D. Number of Hinges: Provide number of hinges indicated but not less than 3 hinges per door leaf for doors 90 inches (2250 mm) or less in height and one additional hinge for each 30 inches (750 mm) of additional height.

2.5 LOCK CYLINDERS AND KEYING

- A. Existing System: Grandmasterkey the locks to the Owner's existing system, with a new masterkey for the Project.

2.6 LOCKS, LATCHES, AND BOLTS

- A. Strikes: Provide manufacturer's standard wrought box strike for each latch or lock bolt, with curved lip extended to protect frame, finished to match hardware set, unless otherwise indicated.
1. Provide flat lip strikes for locks with 3-piece, antifriction latchbolts as recommended by manufacturer.
- B. Lock Throw: Provide 5/8-inch (16-mm) minimum throw of latch on pairs of doors. Comply with UL requirements for throw of bolts and latch bolts on rated fire openings.
1. Provide 1/2-inch (13-mm) minimum throw of latch for other bored and preassembled types of locks and 3/4-inch (19-mm) minimum throw of latch for mortise locks. Provide 1-inch (25-mm) minimum throw for all dead bolts.
- C. Flush Bolt Heads: Minimum of 1/2-inch- (13-mm-) diameter rods of brass, bronze, or stainless steel with minimum 12-inch- (300-mm-) long rod for doors up to 84 inches (2100 mm) in height. Provide longer rods as necessary for doors exceeding 84 inches (2100 mm) in height.

2.7 ELECTRIC STRIKES

- A. Electric Strikes; BHMA A156.31; Grade 1; with faceplate to suit lock and frame.

2.8 ELECTROMAGNETIC LOCKS

- A. Electromagnetic Locks: BHMA A156.23; electrically powered; with electromagnetic attached to frame and armature plate attached to door; full-exterior or full-interior type, as required by the application.

- B. Boxed Power supplies: Locate power supplies as indicated or, if not indicated, above accessible ceilings. Verify location with Architect.
 - 1. Configuration: Provide least number of power supplies required to adequately serve doors with electrified door hardware.

2.9 CLOSERS AND DOOR CONTROL DEVICES

- A. Size of Units: Except as otherwise specifically indicated, comply with the manufacturer's recommendations for size of door control unit depending on size of door, exposure to weather, and anticipated frequency of use.
 - 1. Where parallel arms are indicated for closers, provide closer unit one size larger than recommended for use with standard arms.
 - 2. Provide parallel arms for all overhead closers, except as otherwise indicated.
- B. Access-Free Manual Closers: Where manual closers are indicated for doors required to be accessible to the physically handicapped, provide adjustable units complying with ANSI A117.1 provisions for door opening force and delayed action closing.

2.10 WEATHERSTRIPPING AND SEALS

- A. General: Provide continuous weatherstripping on exterior doors and smoke, light, or sound seals on interior doors where indicated or scheduled. Provide noncorrosive fasteners for exterior applications and elsewhere as indicated.
- B. Replaceable Seal Strips: Provide only those units where resilient or flexible seal strip is easily replaceable and readily available from stocks maintained by manufacturer.
- C. Weather-stripping at Jambs and Heads: Provide bumper-type resilient insert and metal retainer strips, surface applied unless shown as mortised or semimortised.

2.11 THRESHOLDS

- A. General: Except as otherwise indicated, provide standard metal threshold unit of type, size, and profile as shown or scheduled.

2.12 HARDWARE FINISHES

- A. Provide quality of finish, including thickness of plating or coating (if any), composition, hardness, and other qualities complying with manufacturer's standards, but in no case less than specified by referenced standards for the applicable units of hardware.
- B. The designations used in schedules and elsewhere to indicate hardware finishes are the industry-recognized standard commercial finishes, except as otherwise noted.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Mount hardware units at heights indicated in following applicable publications, except as specifically indicated or required to comply with governing regulations and except as otherwise directed by Architect.
 - 1. Recommended Locations for Builders Hardware for Standard Steel Doors and Frames" by the Door and Hardware Institute.
 - 2. NWWDA Industry Standard I.S.1.7, "Hardware Locations for Wood Flush Doors."
- B. Install each hardware item in compliance with the manufacturer's instructions and recommendations. Where cutting and fitting is required to install hardware onto or into surfaces that are later to be painted or finished in another way, coordinate removal, storage, and reinstallation or application of surface protection with finishing work specified in the Division 9 Sections. Do not install surface-mounted items until finishes have been completed on the substrates involved.
- C. Set units level, plumb, and true to line and location. Adjust and reinforce the attachment substrate as necessary for proper installation and operation.
- D. Drill and countersink units that are not factory prepared for anchorage fasteners. Space fasteners and anchors in accordance with industry standards.
- E. Set thresholds for exterior doors in full bed of butyl-rubber or polyisobutylene mastic sealant complying with requirements specified in Division 7 Section "Joint Sealers."
- F. Weather-stripping and Seals: Comply with manufacturer's instructions and recommendations to the extent installation requirements are not otherwise indicated.

3.2 ADJUSTING, CLEANING, AND DEMONSTRATING

- A. Adjust and check each operating item of hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate freely and smoothly or as intended for the application made.
 - 1. Where door hardware is installed more than one month prior to acceptance or occupancy of a space or area, return to the installation during the week prior to acceptance or occupancy and make final check and adjustment of all hardware items in such space or area. Clean operating items as necessary to restore proper function and finish of hardware and doors. Adjust door control devices to compensate for final operation of heating and ventilating equipment.
- B. Clean adjacent surfaces soiled by hardware installation.
- C. Instruct Owner's personnel in the proper adjustment and maintenance of door hardware and hardware finishes.
- D. Six-Month Adjustment: Approximately six months after the date of Substantial Completion, the Installer, accompanied by representatives of the manufacturers of latch sets

and locksets and of door control devices, and of other major hardware suppliers, shall return to the Project to perform the following work:

1. Examine and re-adjust each item of door hardware as necessary to restore function of doors and hardware to comply with specified requirements.
2. Consult with and instruct Owner's personnel in recommended additions to the maintenance procedures.
3. Replace hardware items that have deteriorated or failed due to faulty design, materials, or installation of hardware units.
4. Prepare a written report of current and predictable problems (of substantial nature) in the performance of the hardware.

3.3 HARDWARE SCHEDULE

A. General: Provide hardware for each door to comply with requirements of Section "Door Hardware," hardware set numbers indicated in door schedule, and in the following schedule of hardware sets.

1. Hardware sets indicate quantity, item, manufacturer and product designation, size, and finish or color, as applicable.

Heading No. 1

3 Hinges	AB700 4-1/2" x 4-1/2"	26D
1 Lockset	82 8255 LNJ	26D
1 Closer	350 PSH	EN
1 Threshold	884 V	AL
1 Door Sweep	102 VA x 36"	28D
1 Weather-stripping	160 VA 36" x 84"	28D
1 Electric Strike	Heavy Duty Electric Strike	SS
Door Cylinders: Match Owners Existing System		
Card Reader by Lakeland Security Vendor		

Heading No. 2

6 Hinges	AB700 4-1/2" x 4-1/2"	26D
2 Exit Devices	8813 ETL	26D
2 Locksets	82 8205 LNJ	26D
2 Closers	350 PSH	EN
1 Threshold	884 V x 72"	AL
1 Weather-stripping	160 VA 36" x 84"	28
2 Door Sweeps	102 VA x 36"	Alum
1 Electric Strike	Heavy Duty Electric Strike	SS
1 Removable Steel Mullion 4954		
Door Cylinders: Match Owners Existing System		
Card Reader by Lakeland Security Vendor		

Heading No. 3

3 Hinges	AB700 4-1/2" x 4-1/2"	26D
1 Exit Device	8813 ETL	26D
1 Lockset	82 8205 LNJ	26D
1 Closer	350 PSH	EN
1 Threshold	884 V x 72"	AL
1 Weather-stripping	160 VA 36"x 84"	28
1 Door Sweeps	102 VA x 36"	Alum
1 Electric Strike	Heavy Duty Electric Strike	SS

Door Cylinders: Match Owners Existing System

Card Reader by Lakeland Security Vendor

Heading No. 4

1 Exit Device	8813 ETL	26D
1 Closer	351 CPSH	EN
1 Overhead Stop	690 (Concealed)	26D
1 Threshold	325HD	AL
1 Continuous Hinges	780-224 HD	AN
1 Electric Strike	Heavy Duty Electric Strike	SS

1 Weather-Stripping by Door Manufacturer

Door Cylinders: Match Owners's Existing System

Card Reader by Lakeland Security Vendor

Heading No. 5

3 Hinges	AB700 4-1/2" x 4-1/2"	26D
1 Closer	350 PSH	EN
1 Lockset (Primary)	8867 LNJ	26D
1 Door Protection Plate	8" x 34" SS	

Door Cylinders: Match Owners's Existing System

Heading No. 6

2 Exit Devices	8813 ETL	26D
2 Closers	351 CPSH	EN
2 Overhead Stops	690 (Concealed)	26D
1 Threshold	325HD	AL
2 Continuous Hinges	780-224 HD	AN
1 Electric Strike	Heavy Duty Electric Strike	SS

1 Removable Steel Mullion 4954

Push/Pulls and Weather-Stripping by Door Manufacturer

Card Reader by Lakeland Security Vendor

END OF SECTION 087100