SECTION 260923.00 - LIGHTING CONTROL DEVICES

PART 1 - GENERAL

1.1 SUBMITTAL REQUIREMENTS

A. Product Data
   1. For equipment, materials and systems specified in this section. Include product data, descriptive information, technical data, wiring diagrams, load restrictions, etc.

PART 2 - PRODUCTS

2.1 MANUAL LIGHTING CONTROL DEVICES – SEE SECTION 262726.00

2.2 AUTOMATED LIGHTING CONTROL

A. Digital Timer Switches: Provide Standard of Quality equal to WattStopper TS-400. Provide time range as indicated on drawings or as directed in field based on specific applications. Provide wall plates and finish colors to match color and style specified in section 262726 “Wiring Devices.”

B. Multi-Purpose Time Clock (7 Day): Provide Intermatic #ET2705C series Multi-Purpose Time Clock (or equal by Tork), which is programmable 7-day/365-day with override controls. Provide required external contactors, relays, etc. to render the control systems fully operational. Verify zone control requirements in field prior to rough-in. Provide 100-hour carryover carryover.

PART 3 - EXECUTION

3.1 GENERAL

A. Installation: Provide grounded (“neutral”) conductor in all lighting control device (switch, dimmer, occupancy sensor, etc.) wall outlet boxes, even if not immediately used.

End of Section 260923.00