

SPECIFICATIONS FOR CONSTRUCTION

In general, unless specifically set forth herein, the work, materials, and methods of measurement and payment shall conform to the applicable divisions and paragraphs (as noted on the Bid Proposal or in the plans) of the most current edition of the:

**COMMONWEALTH OF KENTUCKY
TRANSPORTATION CABINET
DEPARTMENT OF HIGHWAYS, FRANKFORT**

Standard Specifications
for
Road and Bridge Construction

SPECIAL PROVISIONS

ITEMS 105.07 / 107.15 - COOPERATION WITH UTILITIES

All portions of Item 105.07 and Item 107.15 of the Kentucky Department of Highways Standard Specifications for Road and Bridge Construction shall apply.

At least two (2) working days prior to commencing construction operations in an area which may involve underground utility facilities as shown on the plans, the Contractor shall notify the Engineer, the registered utility protection service, and the owners of each underground utility facility not members of the registered utility protection service.

The existing underground utilities are shown as accurately as possible on the plans, based on information available. The Owner and/or the Engineer do not assume any liability for location of these underground utility service lines. Any utility services damaged that were previously marked in the field shall be replaced at the Contractor's expense.

COORDINATION WITH UTILITIES

Coordination of work schedules with affected utilities will be required. Upon the contract award, the coordination of all necessary relocations or adjustment of all utility facilities become the responsibility of the Contractor.

ITEM 105.06 - COOPERATION BETWEEN CONTRACTORS

The Contractor shall coordinate his work with other Contractors within or adjacent to the project limits. All improvements completed under this contract shall meet the line and grade of other work in an acceptable manner.

ITEM 106 - CONTROL OF MATERIAL

Unless otherwise specified, all materials shall be new, and both workmanship and materials shall be of proper quality and sufficient for the purpose contemplated. The Contractor shall furnish, if so required, satisfactory evidence as to type and quality of materials and workmanship.

All items of equipment and/or material proposed by the Contractor for substitutions must be approved by the Engineer in writing and shall be equal or superior to the items specified in the contract documents. If said substitution proposed by the Contractor for a specified item requires engineering revisions, the total expense of said revisions shall be paid by the Contractor.

Any items of labor and materials required, but not shown as a separate pay item in the proposal, shall be furnished and installed as incidental to the contract, except as noted in the plans and specifications.

ITEM 106.08 - STORAGE OF MATERIALS

The Contractor shall obtain prior approval in writing from the Owner for the locations to be used for the temporary storage of construction materials, tools, and/or machinery. All such materials, tools, and machinery shall be neatly and compactly piled in such a manner as to cause the least inconvenience to the property owners and to traffic. Under no circumstances shall existing drainage courses be blocked or water hydrants, valves, or meter pits covered. All materials, tools, machinery, etc., stored upon public thoroughfares must be provided with warning lights and reflective sheeting at nighttime and weekends to alert traffic of such obstructions.

ITEM 108.02 - PRECONSTRUCTION CONFERENCE

Prior to the commencement of construction activities, the Engineer will arrange a meeting between the Contractor, the representatives of the Owner, and the representatives of each of the utility companies. The time, date, and location of said meeting will be determined after the awarding of the contract, and the parties will be notified by the Engineer.

The agenda for the preconstruction meeting shall include the following items:

1. Announcement of Award
2. Utility Company Requirements
3. Designation of Emergency 24-hour Contractor Contacts
4. Discussion of Critical Plan Items
5. Review of Testing and Inspection Procedures
6. Operations Schedule
7. Listing of Haul Roads
8. Identification of Subcontractors
9. Review of Change Order Process
10. Payment Request Submittal Procedure

The Contractor shall coordinate all work with the Engineer. A detailed schedule of operations shall be furnished by the Contractor to the Engineer at the preconstruction meeting and shall list the order of operations and the time frame for the completion of each item of work. The schedule of operations shall be approved by the Engineer and the Owner in writing prior to the beginning of the work. Changes to said schedule are to be issued in writing and approved by the Engineer and the Owner before operations are changed or rescheduled. No payment will be made to the Contractor while he is delinquent in the submission of a progress schedule.

The Contractor shall supply to the Engineer at the preconstruction meeting, a list of the local roads to be used for the purpose of hauling equipment and/or material to or from the job site. Only the local roads in the vicinity of the project have to be listed; state and/or federal roads do not have to be included. Where necessary, the list shall include the extent of the roads to be affected and any special restrictions, such as height or weight restrictions, which may be applicable along said roads. Construction shall not commence until the Engineer and/or Owner has reviewed the haul road list and approved the haul roads in writing.

The submission of the list to and the review and approval of the list by the Engineer do not relieve the Contractor of the responsibility for the conforming to and the obeying of all applicable height and weight restrictions on the haul roads and of the responsibility for any damage done to and/or along said haul roads. The Contractor is referred to Item 105.10 concerning load restrictions.

ITEM 107.04 - PERMITS, LICENSES AND TAXES

The Contractor shall insure that all required notices are given and all permits acquired before the commencement of work. The Engineer will discuss any special permits required for this project at the preconstruction meeting.

ITEM 107.14 - CONTRACTOR'S RESPONSIBILITY FOR WORK

It shall be the responsibility of the Contractor to perform his work in such a manner as not to damage or destroy any existing feature (i.e., existing inlets, conduits, etc.), which is not marked for replacement or removal. The Contractor shall exercise due care during construction so as not to destroy any trees, plants, shrubs or structures not specifically marked for removal or relocation within the work limits. In some instances, the Contractor will be required to excavate under and around the existing utilities. Extreme care should be used not to damage the utility during this operation. The Contractor shall schedule his operations so that the improved areas have had sufficient time to cure, set and/or harden before the area is opened to traffic or use. The Contractor shall be responsible for the immediate repair of the improved area if any damage is done by traffic. The Contractor shall also be responsible for the immediate rectification of problems created in areas outside of the improved areas which are attributable to the failure of the improved area, i.e., the tracking of materials into unimproved areas.

The Contractor shall be responsible for the protection of areas outside of the designated work limits, but which may be adjacent to those work limits. This will include those areas used by construction traffic for access to and from the work areas. Where the Engineer and/or the Owner determine that the Contractor's operations have been responsible for damage to areas outside of the work limits, the Contractor shall be responsible for the repair of the area subject to the approval of the Engineer. No additional compensation will be due to the Contractor for any such repairs as described above.

ITEM SPL - JOINT AND CRACK SEALING

The work to be performed consists of the furnishing of all tools, supplies, services, labor, supervision in installation, complete, of the joint and crack sealing material. The item shall consist of providing and installing resilient and adhesive joint sealing filler capable of effectively sealing joints and crack in Portland cement and bituminous cement pavement surfaces.

Joint and crack sealing materials shall meet the following requirements:

ASTM 3405 - Joint Sealant, Hot-Poured for Portland Cement Concrete and Asphalt Pavements.

Prior to the start of construction, the Contractor shall submit to the Engineer a catalog sheet indicating the brand of joint sealant which he proposes to use for the project. It shall be approved by the Engineer in writing prior to ordering the material.

Immediately before sealing the joints and cracks shall be thoroughly cleaned of a foreign material. The joints and cracks shall be routed to width of 3/8 to 1/2 inch and depth of 1/2 to 1 inch. Upon completion of routing, the joints and cracks shall be brushed and blown with compressed air so that the joints and cracks are surface dry when the sealant is applied. Backer rod shall be used as necessary.

The final width of the joint sealant shall be essentially the same width as the crack. An obvious band of sealant on the top surface of the pavements is not acceptable. Any sealant spilled on the surface of the pavement shall be removed immediately.

Installation and heating of the joint and crack sealant shall be as per the manufacturer's recommendations.

The joint sealant shall be applied uniformly solid from the bottom to the top of the crack or joint and shall be filled without formation of any entrapped air voids.

Payment shall be per linear foot and shall be full compensation for furnishing all materials, for all preparation, delivering and placing of these materials, and for all labor, equipment, tools and incidentals necessary to complete the item.

Payment shall be for both joint sealing and random crack sealing.

DEBRIS REMOVAL

The Contractor will be responsible for removal of all construction debris from the site. All debris shall be disposed of in a proper manner and shall be as directed by all applicable local, state, or federal regulations.

CONTROL OF WORK

Construction work shall take place between the hours of 7:00 A.M. to 7:00 P.M., Monday through Saturday.

Driveways and driveway aprons removed shall be formed and poured within 24 hours.

Driveways and driveway aprons may be removed on Thursday, but must be formed and poured on Friday.

Driveways and driveway aprons may not be removed on Friday.

"OR APPROVED EQUAL" ITEMS

In the preparation of these documents and plans, several proprietary products may have been specified. In all such cases, it is to be understood that the Contractor may offer a substitute for the specified product, as indicated by the words "Or Approved Equal." However, the Contractor must be aware that, before commencement of construction, he must provide information to the Engineer concerning the substituted product, and that the Engineer must approve in writing the offered product as being equal to the specified product before use or incorporation into the work.

Unless otherwise modified by the Engineer, proprietary products are to be installed and/or constructed in strict compliance with the pertinent Manufacturer's specifications.

PAYMENT

No adjustments to unit prices shall be due to the Owner or the Contractor for increases or decreases in the Engineer's approximate unit quantities shown in the proposal resulting from changes in the amount of work performed.

THE OWNER RESERVES THE RIGHT TO AWARD OR DELETE ANY OR ALL COMBINATIONS.

ELECTRIC UTILITY NOTES

DUKE ENERGY

1. **DANGER** - Contractor shall contact the company prior to excavation in vicinity of electric underground facilities (approximate plan location shown) or when working near overhead electric facilities.
 - (A) For Field Inspector to locate underground electric line, in Ohio call "Ohio Utilities Protection Service" at 1-800-362-2764, and in Kentucky call "Kentucky Underground Protection Service (KUPS)" at 1-800-752-6007 (at least 48 hours in advance), excluding hours Sat., Sun., and State Legal Holidays.
 - (B) For notification of construction activity near energized electric facilities, call Mr. Bob Schroeder, 287-3426.
 - (C) For additional underground electric record information, call 287-2454.
 - (D) For electric engineering notification, agreements and correspondence, address to Mr. James Dugan, Central Accounting Marketing Section, Duke Energy, P. O. Box 960, Cincinnati, Ohio 45202-0960.
2. Contractor shall be responsible for all damages to electric facilities during construction.
3. Electric facilities to be kept in service at all times.
4. Contractor shall be responsible for supporting existing electric facilities affected by the proposed construction.
 - A. Where high pressure oil filled pipe type cable installations are exposed or otherwise interfered with by the Contractor, protection by the Contractor will be required against damage to the coating or surrounding thermal sand envelope.
 - B. Where concrete encased conduit systems or direct buried cable systems are exposed or otherwise interfered with, the Contractor shall protect the system as necessary against damage. As soon as feasible, the Contractor shall take additional appropriate steps to provide permanent measures to restore support. The methods used shall be based on conditions to be determined by the utility.
 - C. Where poles or anchors that support overhead electric facilities are exposed or otherwise interfered with, the contractor shall protect them from damage and provide temporary support to insure the integrity of the system. As soon as feasible, the Contractor shall take additional appropriate steps to provide permanent measures to restore support. The methods used shall be based on conditions to be determined by the utility.
 - D. Where the depth of excavation for the proposed work is greater than five (5) feet, the Contractor shall sheet and shore the trench to continuously maintain the support of electric facilities at locations where the electric facilities are within the zone of influence adjacent to the excavation as determined by the natural angle of repose of the soil.
 - E. All damage to electric facilities and services requiring adjustments, relocations and/or repairs will be made at the Contractor's cost.
5. Contractor shall not backfill exposed electric facilities until the company has inspected its facility or performed any adjustments and/or maintenance that may be required.

NOTE: Should Contractor damage electric facilities, Contractor shall immediately notify the Electric Service Desk through the Company Operator (381-2000). Contractor shall keep everyone clear of damaged electric facilities until company personnel arrive at the work site.

GAS FACILITY NOTES

DUKE ENERGY COMPANY

Gas Facility Notes

- I. For Gas Engineering Notification, agreements, and official correspondence, address to:

Duke Energy
139 East Fourth Street
P.O. Box 960, Room 460-A
Cincinnati, Ohio 45202
- II. The gas main information provided shows the approximate locations and depths of cover and is provided to comply with statutory regulations. This information should be used only for planning, not construction.
- III. All gas main depths of cover noted are approximate depths of cover recorded at the time of installation. Any resulting grade changes since the time of the main installation will cause the existing depth of cover to be different. Extreme care must be taken to ensure safe excavation when approaching known or suspected gas facilities.
- IV. All gas services were installed at a minimum of 1'-6" of cover. See item III above.
- V. For additional gas facility record information, call 1-800-372-7612.
- VI. To comply with federal and state regulations concerning damage prevention programs, the utility companies must be contacted at least 48 hours (two working days) prior to excavation by calling the OHIO UTILITIES PROTECTION SERVICE (OUPS), toll free, at 1-800-362-2764.

Construction Notes

- I. Gas facilities are to be kept in service at all times.
- II. The contractor shall be responsible for all damages to gas facilities during or as a result of the Contractor's construction. All damage to gas facilities requiring adjustments, relocations and/or repairs will be made at the contractor's cost.

- III. The contractor shall sheet and shore all excavations as required to continuously support gas facilities within the zone of influence (as determined by the natural angle of repose of the soil).
- IV. Crossing buried gas facilities with heavy construction equipment may cause damage to the gas facilities. Contact the Duke Energy Gas Engineering Department for details on how to protect the gas facilities from damage.
- V. The contractor shall not backfill exposed gas facilities until the utility has inspected its facilities and performed any maintenance and/or adjustments that may be required.
- VI. The contractor is responsible for preventing any damage to our gas facilities. This includes protection of coatings and wrappings on steel gas mains. It also includes any damage with may have occurred to plastic gas mains, such as crimps or gouges.
- VII. When cast iron or similar gas facilities are exposed or interfered with by the contractor, replacement or reinforcement by Duke Energy may be required at the contractor's expense. Backfill with control low strength material will be required.
- VIII. Blasting or other construction procedures which may transmit loads or vibrations in the vicinity of gas facilities must be approved by Duke Energy Gas Engineering Department. A blasting plan, identifying all pertinent information, must be submitted in writing by a blasting expert prior to any work.

Proposed Developments at Gas R/W & Easements (If Applicable)

- I. Proposed development plans around and near gas facilities within private easements must be submitted to Duke Energy Gas Engineering Dept. for review. These plans must be approved before any work may begin within our easements.
- II. Specified easement widths must be maintained in order for Duke Energy to protect its facilities.
- III. No permanent structures may be built within the easements.
- IV. Cuts and fills are generally not permitted within the easements. Some fills may be allowed, and will be reviewed on an individual basis. Any permitted fills will be limited to an amount which will allow Duke Energy to properly maintain its facilities.
- V. Perpendicular utility crossings of gas easements are acceptable, provided proper clearances are maintained. Parallel installations are normally not allowed.

WATER WORKS NOTES

All work pertaining to water works items shall be done in strict accordance with the specifications of the Northern Kentucky Water Service District and under the direction, supervision and inspection of the Water District. Water main items are to be constructed in accordance with the provisions of the Kentucky 2000 Transportation Cabinet / Department of Highways, Standard Specifications for Road and Bridge Construction, dated January 1, 2000, and any supplements or changes thereto. Copies of all pertinent specifications may be obtained from the Northern Kentucky Water Service District.

A cushion of 12" shall be maintained between the proposed water mains and the existing sewers, inlet connections, and drains. If a greater clearance is desired, it will be so designated. Building sewer laterals are not to be disturbed or trapped. Existing drains, sewers and culverts are not to be disturbed. If the water main is to be under culverts or pipe sewers, they shall be tunneled and backfilled with Class "T" concrete.

It shall be the Contractor's responsibility to arrange for removal and replacement of any poles and guys necessary for the installation of the proposed water mains, and any cost connected thereto shall be his expense.

All backfill to be Method "A" except where otherwise noted.

No part of any fire hydrant setting shall be installed closer than five feet to any driveway, inlet, utility pole, or guy wire anchor.

No extra payment will be made for lead joints.

SANITARY SEWER NOTES

Sanitary sewer and/or combination sewer items are to be constructed in accordance with the provisions of the Sanitation District No. 1, and under the direction, supervision and inspection of the Sanitation District No. 1. Sanitation sewer items are to be constructed in accordance with the provisions of the Kentucky 2000 Transportation Cabinet / Department of Highways, Standard Specifications for Road and Bridge Construction, dated January 1, 2000, and any supplements or changes thereto.

The Contractor shall supply separate bid items for raising manholes using manhole adjustment rings and for using brick and mortar. If only one bid item is received, the Contractor shall raise all manholes with brick and mortar. Sewer manhole adjustment prior to machine paving shall be done in accordance with the Sanitation District No. 1 Rules and Regulations.

In the event that manhole adjusting rings cannot be used on sanitary and/or storm sewer manholes, the Contractor shall be required to use brick masonry and to adjust manholes to grade. Stacking of adjusting rings shall not be permitted. Substandard or damaged manhole casting shall be replaced with standard casting.