

## **ADDENDUM NO. 1**

### **SCIOTO COUNTY REGIONAL WATER DISTRICT NO.1 WOODS RIDGE WATER STORAGE TANK REPLACEMENT**

Bids will be received until 10:00 A.M., local time, October 29, 2019.

This Addendum to the Project Manual is issued to modify, explain or correct the original Project Manual and is hereby made part of the Contract Documents. Insert the number of this Addendum in the blank space provided in the Bid Form, Section 00400, page 1.

#### **A. DIVISION 00 – PROCUREMENT AND CONTRACTING REQUIREMENTS**

##### **1. SECTION 003100 – INFORMATION AVAILABLE TO BIDDERS**

###### **a. Page 003100-1, PARAGRAPH 1.01 – SUBSURFACE INVESTIGATION REPORT**

REPLACE Paragraph 1.01 in its entirety as follows:

##### **1.01 SUBSURFACE INVESTIGATION REPORT**

A. The following geotechnical report with respect to the project site has been prepared as a service to the Owner:

1. Title: Geotechnical Report, Woods Ridge Water Storage Tank, Portsmouth, Ohio
2. Date: October 21, 2019
3. Prepared by: Terracon Consultants, Inc., Columbus, Ohio

B. A copy of the complete report has been included.

C. This report identifies properties of below grade conditions primarily for the use of the Architect/Engineer.

D. The recommendations described shall not be construed as a requirement of this Contract unless specifically referenced in the Contract Documents.

E. This report, by its nature, cannot reveal all conditions that exist on the site. Should subsurface conditions be found to vary substantially from this report, changes in the design and construction of foundations will be made, with resulting credits or expenditures to the Contract Price accruing to Owner.

#### **B. DIVISION 33 – UTILITIES**

##### **1. SECTION 331613.14 – BOLTED STEEL WATER STORAGE TANKS**

- a. Page 331613.14-1, PART 1 – GENERAL, PARAGRAPH 1.2.C – QUALIFICATIONS OF TANK SUPPLIER

REPLACE within Paragraph 1.2.C the text “Model 2084” with the text “Model 14108”.

- b. Page 331613.14-3, PART 2 – PRODUCTS, PARAGRAPH 2.1.A.11 – PRODUCT INFORMATION, Pipe Materials

REPLACE Paragraph 2.1.A.11 in its entirety as follows:

11. Pipe Materials: Interior inlet/outlet pipe, AWWA C151 ductile iron, PC350. Overflow pipe, Schedule 80 PVC.

- c. Page 331613.14-3, PART 2 – PRODUCTS, PARAGRAPH 2.1.A.12 – PRODUCT INFORMATION, Snow Loading

REPLACE Paragraph 2.1.A.12 in its entirety as follows:

12. Snow Loading: 30 psf.

- d. Page 331613.14-3, PART 2 – PRODUCTS, PARAGRAPH 2.1.A.14 – PRODUCT INFORMATION, Seismic Design

REPLACE Paragraph 2.1.A.14 in its entirety as follows:

13. Seismic Design: Per Ohio Building Code and requirements of AWWA D103: Seismic Zone 1. Occupancy Category III (Ohio Building Code). Seismic Site Classification per Ohio Building Code – D.

- e. Page 331613.14-4, PART 2 – PRODUCTS, PARAGRAPH 2.1.A.16 – PRODUCT INFORMATION, Pipe Connections

REPLACE Paragraph 2.1.A.16 in its entirety as follows:

16. Pipe Connections: 8-inch-diameter inlet/outlet. (Pipe material to be ductile iron in conformance with AWWA C151. Installation and connections shall be by CONTRACTOR.)

- f. Page 331613.14-4, PART 2 – PRODUCTS, PARAGRAPH 2.1.A.16 – PRODUCT INFORMATION, Tank Bottom

ADD the text “adjacent to the tank wall” following the text “interior to the tank” within the second sentence.

C. DRAWINGS

1. SHEET 5 OF 6 – TANK DETAILS

a. DRAIN PIPE WITH REMOVABLE SLIT STOP DETAIL

CLARIFICATION. This detail applies to the inlet/outlet pipe.

\*\*\*\*\*

**BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM  
IN THE SPACE PROVIDED IN THE BID FORM**

\*\*\*\*\*

Issued By: CT Consultants, Inc.  
148 North High Street  
Gahanna, OH 43230

Date: October 23, 2019

