



IF EXISTING PIPE IS D.I.P.
USE LONG SOLID SLEEVES.
OTHERWISE USE TRANSITION
COUPLINGS AS SPECIFIED
IN SECTION 6.

FOR 6" DIA PIPE L=12'
FOR 8" DIA PIPE L=16'
FOR 12" DIA PIPE L=23'
FOR 16" DIA PIPE L=32'

- NOTES:
- 24 HOUR ADVANCED NOTICE MUST BE GIVEN TO ALL AFFECTED RESIDENTS
 - DISINFECT PIPE PER AWWA STANDARDS
 - SEE CONTRACT DOCUMENTS FOR GENERAL NOTES & BEDDING DETAILS
 - RESTRAIN ALL JOINTS FOR ENTIRE LENGTH OF PIPE
 - PROVIDE 18" MINIMUM SEPARATION BETWEEN CROSSING PIPES
 - SAMPLING TAP REQUIRED IF THERE ARE NO HOUSES OR HYDRANTS FOR FLUSHING IN SHUT DOWN AREA (TAP TO BE ABANDONED AFTER TEST)

FIG 2.5.3

LAKE COUNTY DEPARTMENT OF UTILITIES		
WATER MAIN RELOCATION UNDER PROPOSED SEWER (TYP)		
DATE: 08-03	DRAWN BY: -	SCALE: NONE

Copyright - Jul 08 2010 - 4:15pm CT Consultants, Inc.
Drawing name: H:\2010\10088\dwg\10088001.dwg Layout: 10 by: schneidl

REV. NO.	DESCRIPTION	DATE	BY	CHK'D.